

Test Report issued under the responsibility of:



L C I E

TEST REPORT IEC 61008-1 Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) Part 1: General rules	
Report Number	GYB-ESH-P21051894
Date of issue	2021-06-28
Total number of pages	28 pages
Tested by	Rosy Zheng <i>Rosy Zheng</i>
Reviewed by	Wei Gao <i>Gao Wei</i>
Approved by	Stone Shi <i>Stone Shi</i>
Name of Testing Laboratory	The Comprehensive Technical Service Center (Yueqing Branch) of Wenzhou Customs
Applicant's name	ZHEJIANG GEYA ELECTRICAL CO., LTD
Address	Wenzhou Bridge Industrial Zone, Beibaixiang Twon, Yueqing City, Zhejiang Province, China 325603
Test specification:	
Standard	IEC 61008-1:2010+A1:2012+A2:2013 IEC 61008-2-1:1990 (First Edition) EN 61008-1:2012+A1:2014+A2:2014+A11:2015+A12:2017 EN 61008-2-1:1994+A11:1998
Test procedure	Partial tests
Non-standard test method	See summary of testing page 3
<p>This report is governed by, and incorporates by reference, CPS Conditions of Service as posted at the date of issuance of this report at http://www.bureauveritas.com/home/about-us/our-business/cps/about-us/terms-conditions/ and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence, provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents. Unless specific mention, the uncertainty of measurement has been explicitly taken into account to declare the compliance or non-compliance to the specification.</p>	



Test item description	RCCB
Trade Mark	GEYA
Manufacturer.....	ZHEJIANG GEYA ELECTRICAL CO., LTD Wenzhou Bridge Industrial Zone, Beibaixiang Twon, Yueqing City, Zhejiang Province, China 325603
Model/Type reference	GYL10
Ratings	See pages 6 & 7

List of Attachments (including a total number of pages in each attachment):

EU—GD IEC61008 1H see Annex N°.1

EN 61008-1:2012/A11:2015 addition requirement see Annex N°.2

EN 61008-1:2012/A12:2017 addition requirement see Annex N°.3

Summary of testing:**Standard used:****-IEC 61008-1:2010+A1:2012+A2:2013****-IEC 61008-2-1:1990 (First Edition)****-EN 61008-1:2012+A1:2014+A2:2014+A11:2015+A12:2017****-EN 61008-2-1:1994+A11:1998**

This test report is to verified the GYL10 product capable of operating where more severe climatic conditions prevail -25°C to +60°C, the correct operation at low ambient air temperatures -25°C is tested according to the EN 61008 sequence G1 and the correct operation at high ambient air temperatures +60°C is tested according to the EN 61008 sequence G₀ but the upper temperature is set at +60°C which is subject to agreement between manufacturer and user.

-All the samples satisfy to the clauses examined.**Tests performed (name of test and test clause):**

Number of pole	Type	A ₁	A ₂	B	C	D0+D ₁	D0	D2	E	F	G0	G1	EMC tests		
											EN Standard Modify		H	I	J
1P+N Inc=6000A	63A TypeA 30mA	-	-	-	-	-	-	-	-	-	3	3	-	-	-
	16A TypeA 300mA	-	-	-	-	-	-	-	-	-	3	3	-	-	-
3P+N Inc=6000A	63A TypeA 30mA	-	-	-	-	-	-	-	-	-	3	3	-	-	-
	16A TypeA 300mA	-	-	-	-	-	-	-	-	-	3	3	-	-	-

Testing location:

The Comprehensive Technical Service Center (Yueqing Branch) of Wenzhou Customs


Inspection and Quarantine Mansion, jingang Avenue, Liushi, Yueqing, Wenzhou, Zhejiang, P.R.China

Summary of compliance with National Differences: CENELEC


The product fulfils the requirements of EN 61008-1:2012+A1:2014+A2:2014+A11:2015 +A12:2017 and EN 61008-2-1:1994+A11:1998

Copy of marking plate:

1P+N



3P+N



Test item particulars:	
Classification of RCCBs functionally dependent on the line voltage	No
Opening automatically in case of failure of the line voltage	No
- reclosing automatically when the line voltage is restored	Yes / No
- not reclosing automatically when the line voltage is restored	Yes / No
Not opening automatically in case of failure of the line voltage	No
- able to trip in a hazardous situation arising on failure of line voltage	Yes / No
- not able to trip in a hazardous situation arising on failure of line voltage	Yes / No
Type of RCCB	
- type AC.....	Yes / No
- type A	Yes / No
- independent of the line voltage.....	Yes / No
- dependent on the line voltage.....	Yes / No
- without time delay	Yes / No
- with time delay: type S	Yes / No
- enclosed.....	Yes / No
- unenclosed.....	Yes / No
- IP number	20
- for fixed installation	Yes/ No
- for mobile installation	Yes / No
Number of poles.....	1P+N and 3P+N
Ambient air temperature (°C).....	-25 °C to +60°C See Summary of testing page 3
Method of mounting	On rail (IP20)
Method of connection.....	Not associated with the mechanical mounting
Rated residual operating current (A)	30mA; 100mA; 300mA
Rated current (A).....	16A;20A;25A;32A;40A;50A;63A
Rated voltage (V)	230/240V~(1P+N); 400/415V~(3P+N)
Rated impulse withstand voltage (U _{imp})	4kV
Nature of supply	~
Rated frequency (Hz)	50Hz

Rated making and breaking capacity (A) : 500A for In:16A;20A;25A;32A;40A;50A;10In for
In:63A

Rated residual making and breaking capacity (A) : 500A for In:16A;20A;25A;32A;40A;50A;10In for
In:63A

Rated conditional short-circuit current (A)..... : Inc=6000A

Rated conditional residual short-circuit current (A) : IΔc=6000A

Type of terminal : Pillar terminal

Possible test case verdicts:

- test case does not apply to the test object : N/A
- test object does meet the requirement : P (Pass)
- test object does not meet the requirement : F (Fail)

Testing..... :

Date of receipt of test item..... : 2021-05-26

Date (s) of performance of tests : 2021-05-26 to 2021-06-28

General remarks:

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a comma / point is used as the decimal separator.

General product information:

1P+N and 3P+N
230/240V~(1P+N); 400/415V~(3P+N)
Type AC and Type A
In=16A;25A;40A;63A; Inc=IΔc=6000A
500A for In:16A;20A;25A;32A;40A;50A;10In for In:63A
IΔn= 30mA;100mA;300mA
IΔno =15mA;50mA;150mA
Grid distance = 50 mm
Ui= 500V
Uimp=4kV
Material group=IIIa
Screw diameter=5,9mm
50Hz

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

	TEST SEQUENCE G (3 samples) In=63A I Δ n =30mA 1P+N A type	G0-1	G0-2	G0-3	P
--	--	------	------	------	---

9.22	Verification of reliability			
9.22.1	Climatic test based on Clause 4 of IEC 60068-2-3:2000 and IEC 60068-3-4:			
	- number of cycles: 28	28 cycles		P
	- test temperature: upper temperature 55 °C \pm 2 °C	Set at +60 °C		P
	Initial verification:			P
9.9.2.3	- maximum break time at I Δ n (ms)	G0-1 – 26ms G0-2 – 29ms G0-3 – 28ms		P
	No value exceeds the specified limiting value			P
	Additional test for type S:			
	- minimum non-actuating time (ms) at: I Δ n; 0,13 s :	G1 - G2 - G3 -		N/A
	No tripping during tests			N/A
	Climatic test: no tripping during 28 cycles test			P
	Final verification: the RCCB shall trip with a test current of 1,25 I Δ n (ms)	G0-1 – 26ms G0-2 – 21ms G0-3 – 18ms		P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

	TEST SEQUENCE G (3 samples) In=16A I Δ n =300mA 1P+N A type	G0-7	G0-8	G0-9	P
--	---	------	------	------	---

9.22	Verification of reliability			
9.22.1	Climatic test based on Clause 4 of IEC 60068-2-3:2000 and IEC 60068-3-4:			
	- number of cycles: 28	28 cycles		P
	- test temperature: upper temperature 55 °C \pm 2 °C	Set at +60 °C		P
	Initial verification:			P
9.9.2.3	- maximum break time at I Δ n (ms)	G0-7 – 23ms G0-8 – 25ms G0-9 – 25ms		P
	No value exceeds the specified limiting value			P
	Additional test for type S:			
	- minimum non-actuating time (ms) at: I Δ n; 0,13 s :	G1 - G2 - G3 -		N/A
	No tripping during tests			N/A
	Climatic test: no tripping during 28 cycles test			P
	Final verification: the RCCB shall trip with a test current of 1,25 I Δ n (ms)	G0-7 – 24ms G0-8 – 25ms G0-9 – 24ms		P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

	TEST SEQUENCE G (3 samples) In=63A I Δ n =30mA 3P+N A type	G0-4	G0-5	G0-6	P
--	--	------	------	------	---

9.22	Verification of reliability			
9.22.1	Climatic test based on Clause 4 of IEC 60068-2-3:2000 and IEC 60068-3-4:			
	- number of cycles: 28	28 cycles		P
	- test temperature: upper temperature 55 °C \pm 2 °C	Set at +60 °C		P
	Initial verification:			P
9.9.2.3	- maximum break time at I Δ n (ms)	G0-4 – 28ms G0-5 – 25ms G0-6 – 29ms		P
	No value exceeds the specified limiting value			P
	Additional test for type S:			
	- minimum non-actuating time (ms) at: I Δ n; 0,13 s :	G1 - G2 - G3 -		N/A
	No tripping during tests			N/A
	Climatic test: no tripping during 28 cycles test			P
	Final verification: the RCCB shall trip with a test current of 1,25 I Δ n (ms)	G0-4 – 24ms G0-5 – 27ms G0-6 – 21ms		P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

	TEST SEQUENCE G (3 samples) In=16A I Δ n =300mA 3P+N A type	G0-10	G0-11	G0-12	P
--	---	-------	-------	-------	---

9.22	Verification of reliability			
9.22.1	Climatic test based on Clause 4 of IEC 60068-2-3:2000 and IEC 60068-3-4:			
	- number of cycles: 28	28 cycles		P
	- test temperature: upper temperature 55 °C \pm 2 °C	Set at +60 °C		P
	Initial verification:			P
9.9.2.3	- maximum break time at I Δ n (ms)	G0-10 – 27ms G0-11 – 26ms G0-12 – 27ms		P
	No value exceeds the specified limiting value			P
	Additional test for type S:			
	- minimum non-actuating time (ms) at: I Δ n; 0,13 s :	G1 - G2 - G3 -		N/A
	No tripping during tests			N/A
	Climatic test: no tripping during 28 cycles test			P
	Final verification: the RCCB shall trip with a test current of 1,25 I Δ n (ms)	G0-10 – 26ms G0-11 – 28ms G0-12 – 26ms		P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

ANNEX A (NORMATIVE)			
Test sequence and number of samples to be submitted for certification purposes Table A.1 - Test sequences			
Test sequence	Clause or subclause	Test (or inspection)	
A ₁	6 8.1.1 8.1.2 9.3 8.1.3 9.15 9.4 9.5 9.6 9.13 8.1.3 9.25	Marking General Mechanism Indelibility of marking Clearance and creepage distances (external parts only) Trip free mechanism Reliability of screws, current-carrying parts and connections Reliability of terminals for external conductors Protection against electric shock Resistance to heat Clearances and creepage distances (internal parts) Resistance to rusting	
A ₂	9.14	Resistance to abnormal heat and to fire	
B	9.7.7.4 9.7.7.5 b) 9.7.1 9.7.2 9.7.3 9.7.4 9.7.7.2 9.7.5 9.7.6 9.8 9.22.2 9.23	Resistance of the insulation of open contacts and basic insulation against an impulse voltage in normal conditions Verification of the behaviour of components bridging the basic insulation Resistance to humidity Insulation resistance of the main circuit Dielectric strength of the main circuit Insulation resistance and dielectric strength of auxiliary circuits Verification of clearances with the impulse withstand voltage Secondary circuit of detection transformers Capability of control circuits connected to the main circuits etc. Temperature-rise Reliability at 40°C Ageing of electronic components	
C	9.10	Mechanical and electrical endurance	
D	D ₀	9.9	Residual operating characteristics
	D ₁	9.17 9.19	Behaviour in case of failure of the line voltage Unwanted tripping
		9.11.2.3 a)b) 9.16	Behaviour in case of surge currents Performance at $I_{\Delta m}$ Test device
9.12 9.18		Resistance to mechanical shock and impact Non-operating current under overcurrent conditions	
D ₂		9.11.2.3 c)	Verification of the suitability of RCCBs for use in IT-systems
E		9.11.2.4 a)	Coordination at I_{nc}
	9.11.2.2	Performance at I_m	
F	9.11.2.4 b)	Coordination at I_m	
	9.11.2.4 c)	Coordination at $I_{\Delta c}$	

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict
G	9.22.1	Reliability (climatic tests)	
H ^{a)}	IEC 61543 Table 4 - T1.1 IEC 61543 Table 4 - T1.2 IEC 61543 Table 5 - T2.3	Harmonics, interharmonics Signalling voltage Surges	
I	IEC 61543 Table 5 - T2.1 IEC 61543 Table 5 - T2.5 IEC 61543 Table 5 - T2.2	Conducted sine-wave voltages or currents Radiated electromagnetic field Fast transients (burst)	
J	IEC 61543 Table 5 - T2.6 IEC 61543 Table 6 - T3.1	Conducted common mode disturbances in the frequency range lower than 150 kHz Electrostatic discharges	
<p>a) For devices containing a continuously operating oscillator, the test of CISPR 14-1 shall be carried out on the samples prior to the tests of this sequence.</p> <p>b) This test may be done on separate samples.</p>			

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

Table A.2 - Number of samples for full test procedure			
Test sequence ^a	Number of samples	Minimum number of accepted samples ^b	Maximum number of samples for repeated tests ^c
A ₁	1	1	--
A ₂	3	2	3
B	3	2	3
C	3	2	3
D	3	2 ^d	3
D ₂	3	3	3
E	3	2 ^d	3
F	3	2 ^d	3
G	3	2	3
H ^e	3	2	3
I ^e	3	2	3
J ^e	3	2	3

- a) In total a maximum of three test sequences may be repeated.
- b) It is assumed that a sample which has not passed a test has not met the requirements due to workmanship or assembly defects which are not representative of the design.
- c) In the case of repeated tests, all test results must be acceptable.
- d) All samples shall meet the requirements in 9.9.2.1, 9.9.2.2, 9.9.2.3, 9.9.2.4, 9.9.2.5 and 9.11.2.3, as appropriate. In addition, permanent arcing or flashover between poles or between poles and frame shall not occur in any sample during tests of 9.11.2.2, 9.11.2.4 a), 9.11.2.4 b) or 9.11.2.4 c).
- e) At the manufacturer's request, the same set of samples may be subjected to more than one of these test sequences.

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

Table A.3 - Number of samples for simplified test procedure			
Test sequence	Number of samples according to the number of poles ^{a) g)}		
	2-poles ^{b) c)}	3-poles ^{d) f) i)}	4-poles ^{e)}
A ₁	1 max. rating I _N min. rating I _{ΔN}	1 max. rating I _N min. rating I _{ΔN}	1 max. rating I _N min. rating I _{ΔN}
A ₂	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
B	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
C	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
D ₀ + D ₁	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
D ₀	1 for all other ratings of I _{ΔN}		
D ₂	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
E	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
F	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
	3 min. rating I _N max. rating I _{ΔN}	3 min. rating I _N max. rating I _{ΔN}	3 min. rating I _N max. rating I _{ΔN}
G ^{j)}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}	3 max. rating I _N min. rating I _{ΔN}
	3 min. rating I _N max. rating I _{ΔN}	3 min. rating I _N max. rating I _{ΔN}	3 min. rating I _N max. rating I _{ΔN}
H	3 ^{h)} samples of the same rating I _N chosen at random min. rating I _{ΔN}		
I	3 ^{h)} samples of the same rating I _N chosen at random min. rating I _{ΔN}		
J	3 ^{h)} samples of the same rating I _N chosen at random min. rating I _{ΔN}		
a) If a test is to be repeated according to the minimum performance criteria of clause A.2, a new set of samples is used for the relevant test. In the repeated test all test results must be acceptable.			

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

- b) If only 3-pole or 4-pole RCCBs are submitted, this column shall also apply to a set of samples with the smallest number of poles.
- c) Also applicable to 1-pole RCCBs with uninterrupted neutral and 2-pole RCCBs with 1 protected pole.
- d) Also applicable to 3-pole RCCBs with two protected poles
- e) Also applicable to 3-pole RCCBs with uninterrupted neutral and 4-pole RCCBs with 3 protected poles.
- f) This column is omitted when 4-pole RCCBs have been tested.
- g) If only one value of $I_{\Delta N}$ is submitted, min. rating $I_{\Delta N}$ and max. rating $I_{\Delta N}$ are replaced by $I_{\Delta N}$.
- h) Only the highest number of current paths.
- i) If a 3-pole RCCB with 4 current paths and a 4-pole RCCB are submitted, then only the 4-pole RCCB is tested,
with exception of the test of 9.8 of test sequence B for which both types are submitted to the test.
- j) if the requirement to test max. rating I_N and minimum rating $I_{\Delta N}$ does not cover all the possible range of RCBOs, the minimum $I_{\Delta N}$ shall in any case be chosen for the test.

Table A.4 - Test sequences for RCCBs of different classification according to 4.6

Test sequence	Number of samples according to the number of poles ^{a)}		
	2-pole ^{b) c)}	3-pole ^{e)}	4-pole ^{d)}
D ₀ + D ₁	1 max. rating I_N min. rating $I_{\Delta N}$	1 max. rating I_N min. rating $I_{\Delta N}$	1 max. rating I_N min. rating $I_{\Delta N}$
D ₀	1 for all other ratings of $I_{\Delta N}$ with max. $I_{\Delta N}$		

- a) If a test is to be repeated according to the minimum performance criteria of clause A.2, a new set of samples is used for the relevant test. In the repeated test all test results must be acceptable.
- b) If only 3-pole or 4-pole RCCBs are submitted, this column shall also apply to a set of samples with the smallest number of poles.
- c) Also applicable to 1-pole RCCBs with uninterrupted neutral.
- d) Also applicable to 3-pole RCCBs with uninterrupted neutral.
- e) This column is omitted when 4-pole RCCBs are being tested.

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex n° 1

<p>ATTACHMENT TO TEST REPORT IEC 61008-1 EUROPEAN GROUP DIFFERENCES AND NATIONAL DIFFERENCES Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)</p>
<p>Differences according to: EN 61008-1:2012+A1:2014+A2:2014 used in conjunction with EN 61008-2-1:1994 + A11:1998</p>

<i>modify:</i>	TEST SEQUENCE "G₀" In=63A IΔn =30mA 1P+N A type	G₀₋₁	G₀₋₂	G₀₋₃	P
9.22	VERIFICATION OF RELIABILITY				P
9.22.1	Climatic test				P

<i>modify:</i>	TEST SEQUENCE "G₀" In=16A IΔn =300mA 1P+N A type	G₀₋₇	G₀₋₈	G₀₋₉	P
9.22	VERIFICATION OF RELIABILITY				P
9.22.1	Climatic test				P

<i>modify:</i>	TEST SEQUENCE "G₀" In=63A IΔn =30mA 3P+N A type	G₀₋₄	G₀₋₅	G₀₋₆	P
9.22	VERIFICATION OF RELIABILITY				P
9.22.1	Climatic test				P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

<i>modify:</i>	TEST SEQUENCE "G₀" In=16A IΔn =300mA 3P+N A type	G₀₋₁₀	G₀₋₁₁	G₀₋₁₂	P
9.22	VERIFICATION OF RELIABILITY				P
9.22.1	Climatic test				P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

	TEST SEQUENCE "G₁" (add the new test sequence) I_n=63A I_{Δn}=30mA 1P+N A type	#1	#2	#3	
8	requirements for construction and operation				--
<i>add:</i> 8.Z1	BEHAVIOUR OF RCCBS AT LOW AMBIENT AIR TEMPERATURE				--
	RCCBs for use between -25°C and +40°C operate reliably at low ambient air temperature				P
<i>add:</i> 9.Z1	VERIFICATION OF THE CORRECT OPERATION AT LOW AMBIENT AIR TEMPERATURE FOR RCCBS FOR USE AT TEMPERATURES BETWEEN -25° C AND +40° C				--
	RCCBs mounted in enclosure with degree of protection IP 55 and connected for normal use				N/A
	RCCBs in a test chamber at +23°C ± 2°C and rH 90% ± 3%				P
	RCCBs in ON-position without load				P
	Five test cycles performed acc. to figure Z6				P
	No tripping during cycles				P
	At the end of last 6 h period at -25°C an a.c. residual current is passed through one pole (see figure 4a)				P
	- general type:	[ms]	[ms]	[ms]	--
	break time at 1,25 I _{ΔN} not exceeding the value for I _{ΔN} in table 1	25	24	22	P
	- S-type:	[ms]	[ms]	[ms]	--
	break time at 2,5 I _{ΔN} not exceeding the value for 2 I _{ΔN} in table 1				N/A
	Additionally for RCCBs of type A:				P
	Break time with pulsating d.c. residual currents of				P
	- 1,25 I _{ΔN} (general type)				P
	- 2,5 I _{ΔN} (S-type)				N/A
	Multiplied by:	[ms]	[ms]	[ms]	--
	1,4 for I _{ΔN} > 0,01 A	24	25	27	P
	2 for I _{ΔN} ≤ 0,01 A				N/A
	at α = 0°el (test circuit figure 4b)				P
	After test possible to switch on the RCCB without presence of residual current				P

IEC 61008-1					
Clause	Requirement + Test	Result - Remark			Verdict
	TEST SEQUENCE "G₁" (add the new test sequence) I_n=16A I_{Δn} =300mA 1P+N A type	#4	#5	#6	
8	requirements for construction and operation				--
<i>add:</i> 8.Z1	BEHAVIOUR OF RCCBS AT LOW AMBIENT AIR TEMPERATURE				--
	RCCBs for use between -25°C and +40°C operate reliably at low ambient air temperature				P
<i>add:</i> 9.Z1	VERIFICATION OF THE CORRECT OPERATION AT LOW AMBIENT AIR TEMPERATURE FOR RCCBS FOR USE AT TEMPERATURES BETWEEN -25° C AND +40° C				--
	RCCBs mounted in enclosure with degree of protection IP 55 and connected for normal use				N/A
	RCCBs in a test chamber at +23°C ± 2°C and rH 90% ± 3%				P
	RCCBs in ON-position without load				P
	Five test cycles performed acc. to figure Z6				P
	No tripping during cycles				P
	At the end of last 6 h period at -25°C an a.c. residual current is passed through one pole (see figure 4a)				P
	- general type:	[ms]	[ms]	[ms]	--
	break time at 1,25 I _{ΔN} not exceeding the value for I _{ΔN} in table 1	26	27	26	P
	- S-type:	[ms]	[ms]	[ms]	--
	break time at 2,5 I _{ΔN} not exceeding the value for 2 I _{ΔN} in table 1				N/A
	Additionally for RCCBs of type A:				P
	Break time with pulsating d.c. residual currents of				P
	- 1,25 I _{ΔN} (general type)				P
	- 2,5 I _{ΔN} (S-type)				N/A
	Multiplied by:	[ms]	[ms]	[ms]	--
	1,4 for I _{ΔN} > 0,01 A	28	15	24	P
	2 for I _{ΔN} ≤ 0,01 A				N/A
	at α = 0°el (test circuit figure 4b)				P
	After test possible to switch on the RCCB without presence of residual current				P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

	TEST SEQUENCE "G₁" (add the new test sequence) I_n=63A I_{Δn}=30mA 3P+N A type	#7	#8	#9	
8	requirements for construction and operation				--
<i>add:</i> 8.Z1	BEHAVIOUR OF RCCBS AT LOW AMBIENT AIR TEMPERATURE				--
	RCCBs for use between -25°C and +40°C operate reliably at low ambient air temperature				P
<i>add:</i> 9.Z1	VERIFICATION OF THE CORRECT OPERATION AT LOW AMBIENT AIR TEMPERATURE FOR RCCBS FOR USE AT TEMPERATURES BETWEEN -25° C AND +40° C				--
	RCCBs mounted in enclosure with degree of protection IP 55 and connected for normal use				N/A
	RCCBs in a test chamber at +23°C ± 2°C and rH 90% ± 3%				P
	RCCBs in ON-position without load				P
	Five test cycles performed acc. to figure Z6				P
	No tripping during cycles				P
	At the end of last 6 h period at -25°C an a.c. residual current is passed through one pole (see figure 4a)				P
	- general type:	[ms]	[ms]	[ms]	--
	break time at 1,25 I _{ΔN} not exceeding the value for I _{ΔN} in table 1	25	26	25	P
	- S-type:	[ms]	[ms]	[ms]	--
	break time at 2,5 I _{ΔN} not exceeding the value for 2 I _{ΔN} in table 1				N/A
	Additionally for RCCBs of type A:				P
	Break time with pulsating d.c. residual currents of				P
	- 1,25 I _{ΔN} (general type)				P
	- 2,5 I _{ΔN} (S-type)				N/A
	Multiplied by:	[ms]	[ms]	[ms]	--
	1,4 for I _{ΔN} > 0,01 A	23	25	34	P
	2 for I _{ΔN} ≤ 0,01 A				N/A
	at α = 0°el (test circuit figure 4b)				P
	After test possible to switch on the RCCB without presence of residual current				P

IEC 61008-1					
Clause	Requirement + Test	Result - Remark			Verdict
	TEST SEQUENCE "G₁" (add the new test sequence) I_n=16A I_{Δn} =300mA 3P+N A type	#10	#11	#12	
8	requirements for construction and operation				--
<i>add:</i> 8.Z1	BEHAVIOUR OF RCCBS AT LOW AMBIENT AIR TEMPERATURE				--
	RCCBs for use between -25°C and +40°C operate reliably at low ambient air temperature				P
<i>add:</i> 9.Z1	VERIFICATION OF THE CORRECT OPERATION AT LOW AMBIENT AIR TEMPERATURE FOR RCCBS FOR USE AT TEMPERATURES BETWEEN -25° C AND +40° C				--
	RCCBs mounted in enclosure with degree of protection IP 55 and connected for normal use				N/A
	RCCBs in a test chamber at +23°C ± 2°C and rH 90% ± 3%				P
	RCCBs in ON-position without load				P
	Five test cycles performed acc. to figure Z6				P
	No tripping during cycles				P
	At the end of last 6 h period at -25°C an a.c. residual current is passed through one pole (see figure 4a)				P
	- general type:	[ms]	[ms]	[ms]	--
	break time at 1,25 I _{ΔN} not exceeding the value for I _{ΔN} in table 1	25	24	28	P
	- S-type:	[ms]	[ms]	[ms]	--
	break time at 2,5 I _{ΔN} not exceeding the value for 2 I _{ΔN} in table 1				N/A
	Additionally for RCCBs of type A:				P
	Break time with pulsating d.c. residual currents of				P
	- 1,25 I _{ΔN} (general type)				P
	- 2,5 I _{ΔN} (S-type)				N/A
	Multiplied by:	[ms]	[ms]	[ms]	--
	1,4 for I _{ΔN} > 0,01 A	24	15	19	P
	2 for I _{ΔN} ≤ 0,01 A				N/A
	at α = 0°el (test circuit figure 4b)				P
	After test possible to switch on the RCCB without presence of residual current				P

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex n° 2

<p>ATTACHMENT TO TEST REPORT IEC 61008-1</p> <p>Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)</p>
<p>Differences according to: EN 61008-1:2012/A11:2015</p>

	ANNEX ZB	N/A
	Special national conditions	
Ireland	For RCCBs, functionally dependant on line voltage IEC 61008-2-2 applies in conjunction with Part 1.	N/A
Switzerland	In Switzerland, the use of RCCBs of type AC is not permitted.	N/A

IEC 61008-1			
Clause	Requirement + Test	Result - Remark	Verdict

Annex n° 3


<p>ATTACHMENT TO TEST REPORT IEC 61008-1</p> <p>Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)</p>
<p>Differences according to: EN 61008-1:2012/A12:2017</p>

	ANNEX ZC Special national conditions	N/A
Belgium	The Belgian regulation for Electrical Installation (Art 251, part 5) requires that RCCB' s ≤ 40 A installed at the head-end in household electrical installation, upstream the first overcurrent protection, shall withstand an $I^2 t$ value not less than 22,5 kA ² s at 3000 A and shall be additionally marked with at least the following data: "3000 A, 22,5 kA ² s" .	N/A
	This marking shall remain visible after installation.	N/A


GYL10

1P+N 63A A type 30mA


Over View




Side View



Side View




Bottom View




3P+N 63A A type 30mA


Over View



Side View



Side View



Bottom View

